

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRSUBD20230682  
Address: 1501 SW ARBORWALK BLVD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection:                             | Inspector:     | Outcome: | Date:                      |
|---|----------------|----------|----------------------------|
| <b>Sanitary - Material Verification</b> | Dustin Agcopra | Passed   | Thursday, January 23, 2025 |

|                |   |
|----------------|---|
| Informational: |   |
| 1 Misc         | 2-12-24 PS Verified that approved materials for creek crossing at 21+00, 10" Certa-Flo restrained joint line and max adaptors for connecting unrestrained sections to restrained sections per revised details |

**Comments:**