

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244903
Address: 2620 NE WOODLAND OAK DR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Khanh Nguyen	Failed	Thursday, January 23, 2025

Corrective Action Required:

1 Misc

****RESTORE EROSION CONTROL ALONG THE STREET**

- Provide a wall receptacle at foyer wall wider than 3 ft
- Install roof plumbing penetrations flashing
- Shim gap under garage exterior wall stud
- Move items away from garage wall
- Fb garage chase from ceiling space
- Connect and seal ducts joint below rear dining 18" lvl point load
- Solid block under 18" point load
- Fb basement wall plate penetrations; fb wall from ceiling space
- Complete installing basement bathroom fan

****OK TO INSULATE**

Comments: