

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20245370
Address: 2737 NE MCBAINE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Khanh Nguyen	Ready for Temp CO	Thursday, January 23, 2025

Corrective Action Required:

1	Misc	-Fire approval required -Receptacle located within six ft of lounge sink must be gfci-protected -Move exit sign to directly above exit egress door -Provide return air grill above vestibule
---	------	---

Comments: