

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

STOP WORK ORDER

**ANY UNAUTHORIZED PERSON REMOVING THIS NOTICE WILL BE
PROSECUTED**

Permit #: PRRES20245058
Address: 2606 SW TRACKER LN, LEES SUMMIT, MO 64082

Any person who shall continue work after having been served with a stop work order, except such work as that person is directed to perform to remove a violation or unsafe condition, shall be subject to penalties as prescribed by law.

Inspection:	Inspector:	Outcome:	Date:
Underslab Plumbing Inspection - Residential	Mitchell Schwarz	Failed - Stop Work	Thursday, January 23, 2025

Corrective Action Required

1	Misc	Underslab plumbing covered without inspection. Stop work issued. Schedule for dye test and submit reasoning as to why this was not inspected.
		Inspection denied -erosion control not in compliance -no address posted

Comments: