

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20243996
Address: 3212 SW ARBORIDGE DR, LEES SUMMIT, MO 64082
Inspected On: Thursday, January 23, 2025
Inspected By: Development Center
Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Thursday, January 23, 2025

Corrective Action Required:

1	Misc	-address pending driveway and sidewalk inspections -final grade and sod -install gutters -splash blocks and sump pump discharge to extend 36" from foundation -provide as graded plot plan -uncover covered water meter
---	------	--

Comments: