CITY OF LEE'S SUMMIT

Development Services Department 220 SE Green Street Lee's Summit, MO 64063 FAX (816) 969-1201 (816) 969-1200

Temporary Certificate of Occupancy

Permit #: PRRES20242079

Address: 1604 SW BUCKTHORN ST, LEES SUMMIT, MO 64082

Inspected On: Friday, January 24, 2025 **Inspected By: Development Center**

Expiration Date:

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Mitchell Schwarz Ready for Temp CO Thursday, January 23, 2025

Residential

Corrective Action Required:

- Upload engineer report on pier changes from plans Misc

- Uncover manhole

- Uncover water meter for inspection

- Pending sidewalk inspection

- Final grading and sod

- Install gutters and downspouts

- Provide splash pads

- Sump discharge to be 36" away from foundation

Comments: