

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241493
Address: 2120 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------|----------|-----------------------------|
| Erosion Control Inspection Residential | Robb Popp | Failed | Friday, January 24, 2025 |

Corrective Action Required:

| | | |
|---|---|--|
| 2 | DCM1 ESC REQUIRED NO FURTHER INSP | EROSION CONTROL REQUIRED. NO FURTHER INSPECTIONS WILL BE PERFORMED UNTIL EROSION CONTROL IS INSTALLED AND IN COMPLIANCE. -Re establish erosion control methods at perimeter, Maintain gravel filter with min 6" lift of min 3/4" gravel |
|---|---|--|

Comments: