

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245112
Address: 3215 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|------------------|----------|--------------------------|
| All Rough Inspection - Residential | Mitchell Schwarz | Failed | Friday, January 24, 2025 |

Corrective Action Required:

| | | |
|---|------|---|
| 3 | Misc | -provide attic access above single car garage -anchor bolts at garage doors to be in middle 1/3 of sill plate -missing roof boots throughout -protect NM within 6' of attic access -seal penetration in flooring at owners entry -seal bottom plate penetrations in pantry -seal top plate penetrations in primary bathroom -seal bottom plate penetration at stairwell/primary bed -seal bottom plate penetration great room exterior wall |
|---|------|---|

Comments: