

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20242275
Address: 630 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Failed	Monday, January 27, 2025

Informational:

1	Miscellaneous Correction	- Exterior sheathing inspection only. Passed and is okay to cover -Walls behind cooler ok to cover **Partial only, above ceiling framing and MEPs incomplete -Secure all mc within 12" of boxes -Install anchor bolt within 12" of plate break at south wall -Fireblock ceiling line throughout
---	--------------------------	--

Comments: