

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20236587  
Address: 1404 NE ERNEST WAY, LEES SUMMIT, MO 64086

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Residential</b>	Shawn Hoffman	Ready for Temp CO	Friday, December 27, 2024

Corrective Action Required:

1	Misc	-Obtain lawn irrigation permit and submit backflow valve test report to city -Sidewalk and driveway not approved on record -As-graded plot plan is required -Final grade, sod, downspout and sump pump extension -Seal exterior wall penetrations; seal above meter,
---	------	--

Comments: