

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20246139
Address: 2117 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Robb Popp	Failed	Tuesday, January 28, 2025

Corrective Action Required:

1	DCM2 ESC DEFICIENT INSTALLATION	1/28/25 DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS UNTIL ADEQUATE EROSION CONTROL PROVIDED. -Re establish erosion control methods at perimeter, maintain gravel filter with min 6" lift of min 3/4" gravel, remove all loose trash from site, clean silt, gravel and trash from street
---	---------------------------------------	---

Comments: