

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20246139
Address: 2117 NW OBRIEN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Tuesday, January 28, 2025

Corrective Action Required:

1	Miscellaneous Correction	Partial inspection only: -PFH, front porch roof framing and zip board approved to cover *Back covered deck roof framing-Missing hold down screws at hips, both sides and at right side beam connection
---	--------------------------	--

Comments: