

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20245318  
Address: 2750 SW 11TH TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Tuesday, January 28, 2025

Corrective Action Required:

1	Misc	- Covered porch approved - Portal frame, Approved
---	------	--

Corrective Action Required:

2	Misc	- Add hanger on joist in kitchen - Strap top plate were over bored for DWV in dining/ great room - Security block front door - Provide roof boots on DWV - Nail off triple girder truss in front bedroom
---	------	--

**Comments:**