

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245112
Address: 3215 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Tuesday, January 28, 2025

Corrective Action Required:

1	Misc	-protect NM within 6' of attic access -anchor bolts at garage doors to be in middle 1/3 of sill plate -missing roof boots throughout -protect NM within 6' of attic access
---	------	---

Comments: