

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20242275
Address: 630 NW CHIPMAN RD, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Robb Popp	Partial	Tuesday, January 28, 2025

Informational:

1	Miscellaneous Correction	- Exterior sheathing inspection only. Passed and is okay to cover -Walls behind cooler ok to cover **Partial only, above ceiling framing and MEPs incomplete -Walls approved to cover
---	--------------------------	--

Comments: