

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816) 969-1200 FAX (816) 969-1201

Temporary Certificate of Occupancy

Permit #: PRRES20241766
Address: 2066 NW OBRIEN RD, LEES SUMMIT, MO 64081
Inspected On: Tuesday, January 28, 2025
Inspected By: Development Center
Expiration Date: 2/2/2025 12:00:00 AM

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. **Do not cover any work until approved.**

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Robb Popp	Ready for Temp CO	Tuesday, January 28, 2025

Corrective Action Required:

1	Misc	- land sewer trace wire - final grading and sod - Provide gutters - Provide down spouts and splash blocks - Address center deck post cut flush
---	------	--

Occupancy Inspection - Codes Residential	Mitchell Schwarz	Ready for Temp CO	Friday, January 03, 2025
---	------------------	-------------------	--------------------------

Corrective Action Required:

1	Misc	- land sewer trace wire - final grading and sod - Provide gutters - Provide down spouts and splash blocks - Address center deck post cut flush
---	------	--

Comments: