

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244650
Address: 1021 SW REDBUCK CIR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Tuesday, January 28, 2025

Corrective Action Required:

2	Misc	<ul style="list-style-type: none">- Protect wiring under windows in bedroom 2- Fire block top plate above refrigerator (double wall)- Provide second stud under double 2x10" above refrigerator- Fire block top of chase in basement shower- Fire block basement fur out walls every 10' vertically with approved material (pressure treated)
---	------	---

Comments: