



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRCOM20115339, Building Permit - Commercial
Address: 1229 NE DOUGLAS ST, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Above Ceiling Inspection	Mike Copeland	Failed	Monday, November 28, 2011

Corrective Action Required
1 MISC

ROMEX (NON-METALLIC) ELECTRICAL CONDUCTORS ARE NOT LISTED FOR USE IN COMMERCIAL CONSTRUCTION IN UN-CONCEALED SPACED (ABOVE CEILING).

INSTALL PROTECTIVE RUNNING BOARDS FOR EXISTING CONDUCTORS ABOVE CEILING FOR NM CONDUCTORS, OR INSTALL MC CABLE.

Comments: