

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20246159  
Address: 3230 SW PERGOLA PARK DR, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Wednesday, January 29, 2025

Corrective Action Required:

- |   |      |   |
|---|------|---|
| 1 | Misc | <ul style="list-style-type: none"><li>- Provide access to UFER</li><li>- Provide access to clean out for sewer</li><li>- Fire block top of fir out at TV location to prevent fire and gases in to joist space</li><li>- If shower drain needs to move call in an under slab plumbing inspection</li></ul> |
|---|------|---|

**Comments:**