

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243851
Address: 2139 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Wednesday, January 29, 2025

Corrective Action Required:

1	Miscellaneous Correction	-Missing (2) 2x4 at owners entry -LIB IN PANTRY TO BE 5' 9", -LIB IN UTILITY TO BE 5' 2" -Missing (2) 2x4 at utility closet window -Missing (2) 2x6 at utility closet corner -Missing (2) 2x4 at deck doorway -Protect electrical at master bed return air space-PAN OFF BOX -Missing (2) 2x4 at bed 4 windows -Missing (2) 2x4 bed 4 closet -Missing double 2x4s throughout bed 5 and shared bath
---	--------------------------	---

Comments: