## CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

## **Inspection Summary**

Permit #:PRRES20244024Address:3203 SW ARBOR SOUND DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, January 30, 2025
Corrective Action Required:			
1 Misc	Front pfh and exterior nailing okay to cover.		
Corrective Action Required:			
2 Misc			
	<ul> <li>Nail off girder truss and provide hold down device at primary bedroom</li> <li>Provide stud shoes on bearing wall primary bathroom at vanity to close to edge and to many consecutive studs over board and</li> <li>provide access for clean out under basement stairs</li> </ul>		

**Comments:**