

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245176
Address: 3219 SW ARBORIDGE CIR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Mitchell Schwarz	Failed	Thursday, January 30, 2025

Corrective Action Required:

1 Misc

- address trusses b8, b7 attached to blocking and siding block above garage
- strap top plate where lapped less than 24" above primary walk in closet
- address over board exterior wall studs in primary bath
- provide anchor bolts within 12" of plate breaks in basement
- identify ufer ground connection at both ends and connect to main point of disconnect

Comments: