

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245644

Address: 1403 SW WINTHROP TER, LEES SUMMIT, MO 64081
1401 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Kyle Beard	Failed	Thursday, January 30, 2025

Corrective Action Required:

4	Miscellaneous Correction	Replace or repair silt fence that has been damaged along the front south side, NW corner and along the north side of the lot
---	-----------------------------	--

Full erosion control measures must be in place and properly maintained until CofO

Comments: