

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRPR20250302
Address: 1901 NE PARK RIDGE DR, LEES SUMMIT, MO 64064

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Electrical Service Inspection	Shawn Hoffman	Partial	Thursday, January 30, 2025

Corrective Action Required:

1	Misc	- OK for Evergy to energize first means of disconnect complete
		PARTIAL
		- panel lables, all breakers not in, EV charger not installed at this time

Comments: