



January 30, 2025

Whitney Neese  
New Mark Homes, LLC  
5207 NW Crooked Road  
Parkville, MO 64152

RE: 24-342  
2139 NW Killarney Ln / Lot 131 Woodside Ridge  
Lee's Summit, MO 64081-4093

**PLAN REVIEW RESPONSE: PRRES20243851**

Dear Whitney Neese,

This document shall serve as a response to the structural plan review comments for above referenced project ("Project").

**Comment 1:** Clarification required on amount of jack studs and king studs in a header stud pack.

**Response 1:** For all typical headers and unlabeled headers with (2) studs in a stud pack, the stud pack shall consist of (1) jack and (1) king stud. For all stud packs with (3) studs, the stud pack shall consist of (1) jack stud and (2) king studs.

Where any requirements of the previously issued documents are modified, or deleted, the unaltered provisions shall remain in effect.

Please call if Apex Engineers, Inc. can be of further assistance.

Best Regards,  
Apex Engineers, Inc.

Connor Hobart  
*Project Engineer*