

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20243136
Address: 1408 NE ERNEST WAY, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Friday, January 31, 2025

Corrective Action Required:

1	Misc	-Plan shows the front porch double 2x10 beam and support post. If this is not built per house plan, then this must be addressed by the roof truss engineer
---	------	--

ok to rock

Comments: