

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245643

Address: 1409 SW WINTHROP TER, LEES SUMMIT, MO 64081
1407 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Kyle Beard	Failed	Friday, January 31, 2025

Corrective Action Required:

1	Miscellaneous Correction	Repair or replace damaged silt fence at the front of the lot next to the street
---	-----------------------------	---

Comments: