



CITY OF LEE'S SUMMIT  
CODES ADMINISTRATION  
220 SE GREEN ST.  
P.O.BOX 1600

PHONE:  
816-969-1200

FAX:  
816-969-1201

## Inspection Summary

---

Permit #: PRCOM20115824, Building Permit - Commercial  
Address: 255 NW BLUE PKWY, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

---

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	John Borns	Failed	Tuesday, November 29, 2011

### Corrective Action Required

1	MISC	SOFT/LOOSE ELECTRICAL RECEPTACLES >> CHECK ALL AND TIGHTEN AS REQUIRED
2	MISC	BACKSET AT MICROWAVE OVEN RECEPTACLE NOT NEC CONFORMING -- REQUIRES SPARK RING
3	MISC	BACKFLOW PREVENTION DEVICE REQUIRED FOR WATER FEED TO ICE MAKER
4	MISC	PROVIDE UPDATED ELECTRICAL PANEL SCHEDULE WITH ACCURATE, CLEAR, LEGIBLE LABELS
1		NEED ADDRESSING ON EXTERIOR DOORS

<b>Above Ceiling Inspection</b>	John Borns	Passed	Tuesday, November 29, 2011
-------------------------------------	------------	--------	----------------------------

<b>Occupancy Inspection - Fire</b>	Brian Austerman	Temporary C of O	Tuesday, November 29, 2011
--	-----------------	------------------	----------------------------

**Comments:**