

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244110
Address: 2764 SW 11TH ST, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Final Building Inspection - Residential	Shawn Hoffman	Failed	Monday, February 03, 2025

Corrective Action Required:

1	Misc	- Fire Protect under stringers of stairs - AFCI protection required for all basement lights and outlets - Label sub panel
---	------	---

Comments: