# CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200

# **DEVSERVICES.CITYOFLS.NET**

# **Inspection Summary**

Permit #: PRRES20240001

Address: 2604 NE WOODLAND OAK DR, LEES SUMMIT, MO 64086

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection: Inspector: Outcome: Date:

Occupancy Inspection - Codes Khanh Nguyen Failed Monday, February 03,

Residential 2025

### Corrective Action Required:

1 Misc -Driveway and sidewalk not approved on record

-Final grade, sod, downspout and sump pump extension

-Seal exterior wall hole at sewer pump control, seal exterior wall penetrations;

seal above meter, AC disconnect, seal exterior lights, etc

-Provide sewer tracer wire port at grade

-Provide guardrail at open side of front stoop more than 30" above final grade,

as measure from 36" out from edge down to grade

-Luminaire inside master closet shall be completely enclosed lamp type; luminaire inside upper floor closet shall be completely enclosed lamp type

-Pendant light cannot be located within master bathroom tub zone

-Maximum stair riser height shall be no more than 3/8"

-Glazing in the pantry door shall be safety tempered glazing

-Support furnace intake&exhaust pipes every 5 ft

## **Comments:**