

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20244707  
Address: 840 NW PRYOR RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Foundation Inspection - Commercial</b>	Robb Popp	Failed	Monday, February 03, 2025

Corrective Action Required:

1	Misc	Provide #3 STIRRUPS AT 2" OC FOR FIRST 1'-0" THEN 8" OC FOR REMAINDER, ANDc#4 VERTICAL BARS AT EACH ANCHOR AT PIER PILASTER LOCATIONS
---	------	---

**Comments:**