

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20246494  
Address: 2734 SW HEARTLAND RD, LEES SUMMIT, MO 64082

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Water Service Inspection - R</b>	Kyle Beard	Failed	Monday, February 03, 2025

Informational:

1	Miscellaneous Correction	About 50 feet of PEX has been run out from the foundation to the street and is okay to cover
---	--------------------------	--

This is a partial pass only

**Comments:**