

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20235207  
Address: 2931 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Above Ceiling Inspection</b>	Khanh Nguyen	Partial	Monday, February 03, 2025

Corrective Action Required:

1	LOWER LEVEL	Ok to rock: -Corridor ceiling (top of 1-hr fire barrier), fire sprinler drops
---	-------------	--

Corrective Action Required:

2	FIRST FLOOR	OK to rock: -Corridor ceiling (top of 1-hr fire barrier), fire sprinler drops
---	-------------	--

**Comments:**