

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOM20235207
Address: 2931 SE SHENANDOAH DR, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Commercial	Khanh Nguyen	Failed	Monday, February 03, 2025

Informational:
1 Misc -Nailing of exterior wall sheathing-OK to cover front, north, and south walls

Corrective Action Required:
2 Misc Front garage PFH walls only:
-Provide 2 anchors per wall sill plate
-Nail wall top plate to header w/ 2 rows of 16d @ 3" oc

Comments: