



CITY OF LEE'S SUMMIT
CODES ADMINISTRATION
220 SE GREEN ST.
P.O.BOX 1600

PHONE:
816-969-1200

FAX:
816-969-1201

Inspection Summary

Permit #: PRDEM20115691, Demolition

Address: 3381 NW CHIPMAN RD, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please call for re-inspection once all corrective actions have been completed. Do not cover any work until approved.

Inspection:

Inspector:

Outcome:

Date:

Final Demo

John Borns

Failed

Wednesday, November 30, 2011

Corrective Action Required

1 MISC

DOCUMENTATION REQUIRED THAT NATURAL GAS, SANITARY SEWER, WATER, AND ELECTRICAL SERVICES HAVE BEEN TERMINATED PROPERLY. FORM MAILED TO CONTRACTOR 11/30/2011.

Comments: