

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244002

Address: 219 NW ORCHARD CT, LEES SUMMIT, MO 64063 217 NW ORCHARD CT, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Robb Popp	Failed	Tuesday, February 04, 2025

Corrective Action Required:

3	DCM3 ESC REQUIRED 2 DAY	2/4/25 EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. -Provide erosion control methods at perimeter -Maintain gravel filter with min 6" lift of min 3/4" gravel -Post address -Properly protect storm inlets
---	----------------------------	--

Comments: