

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20244003

Address: 225 NW ORCHARD CT, LEES SUMMIT, MO 64063 223 NW ORCHARD CT, LEES SUMMIT, MO 64063

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Erosion Control Inspection Residential</b>	Robb Popp	Failed	Tuesday, February 04, 2025

Corrective Action Required:

2	DCM3 ESC REQUIRED 2 DAY	EROSION CONTROL REQUIRED. EROSION CONTROL SHALL BE IN COMPLIANCE WITHIN TWO BUSINESS DAYS. -Provide erosion control methods at perimeter -Maintain gravel filter with min 6" lift of min 3/4" gravel -Post address -Properly protect storm inlet
---	----------------------------	--

**Comments:**