

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244071
Address: 2614 SW TRACKER LN, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Failed	Tuesday, February 04, 2025

Corrective Action Required:

- | | | |
|---|------|--|
| 1 | Misc | - Fire block top of HVAC chase in mud hall around 4" DWV |
| | | - Support top of hip rafter in master bedroom |
| | | - Fire block gap at top of HVAC chase behind upstairs shower |
| | | - Fire block top of fur out exterior wall basement stairs |
| | | - Address deck ledger attachment and anchor to code |

Comments: