CITY OF LEE'S SUMMIT Development Services Department 220 SE Green Street Lee's Summit, MO 64063 (816)969-1200 **DEVSERVICES.CITYOFLS.NET**

Inspection Summary

Permit #:PRRES20242933Address:2218 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Erosion Control Inspection Residential	Robb Popp	Failed	Wednesday, February 05, 2025
Corrective Action Required:			
1 Misc	-Clean silt and debris from storm inlet -Protect storm inlet by proper means (gutter buddy needs needs replaced and separated from inlet with cinder blocks)		

Comments: