

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRRES20244826

Address: 1421 SW WINTHROP TER, LEES SUMMIT, MO 64081  
1419 SW WINTHROP TER, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>All Rough Inspection - Residential</b>	Shawn Hoffman	Failed	Wednesday, February 05, 2025

Corrective Action Required:

1 Misc

1419

- Provide security blocking at front door hinges side

1421

- provide security blocking at front door, hinges side

- Missing nails in joist hangers in basement hallway near stairs

- No pressure on gas line

**Comments:**