

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245536
Address: 1102 SW FIORD DR, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Shawn Hoffman	Not Ready	Wednesday, February 05, 2025

Corrective Action Required:

1	Misc	PORTAL FRAME ONLY
		- GARAGE OK TO COVER
		- FRONT PORCH FRAMING OK TO COVER

Corrective Action Required:

2	Misc	INSPECTION DENIDE NO FIRE BLOCKING
---	------	------------------------------------

Comments: