

CITY OF LEE'S SUMMIT  
Development Services Department  
220 SE Green Street  
Lee's Summit, MO 64063  
(816)969-1200  
**DEVSERVICES.CITYOFLS.NET**

## Inspection Summary

Permit #: PRCOM20231975  
Address: 1550 SE HAMBLER RD, LEES SUMMIT, MO 64081

---

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
<b>Occupancy Inspection - Codes Commercial</b>	Shawn Hoffman	Failed	Wednesday, February 05, 2025

Corrective Action Required:

- |   |      |  |
|---|------|--|
| 4 | Misc | <ul style="list-style-type: none"><li>- All outlets in kitchen to be GFCI</li><li>- Complete installation of all stall doors in bathrooms</li><li>- Protect under stairs space under stairs of mezzanine front side until 6' 8" is achieved</li><li>- Provide permanent ladders to roof access in accordance to 306.5 of the international mechanical code</li><li>- Paint gas lines on roof</li><li>- Label Roof Top Units</li><li>- Some GFCI's at RTU's not working</li><li>- Anchor trash compactor motor equipment</li><li>- electrical hanging out of wall 20' up over trash unit. South wall.</li></ul> |
|---|------|--|

**Comments:**