

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRCOMCOM20243640
Address: 500 SW 3RD ST, Unit:A, LEES SUMMIT, MO 64063

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Commercial	Robb Popp	Failed	Thursday, February 06, 2025

Corrective Action Required:

1	Misc	-Mount fire extinguisher -Provide GFCI protection at mechanical, by sink in kitchen and at coffee maker
---	------	------------------------------------------------------------------------------------------------------------

Comments: