S LEE'S SUMMIT MISSOURI

DEVELOPMENT SERVICES

Residential Plan Review

February 06, 2025

KEVIN HIGDON CONSTRUCTION, LLC P O BOX 847 LEES SUMMIT, MO 64063 (816) 524-9797

| Permit No: | PRRES20250416 |
|------------------|--|
| Plan Name: | |
| Project Address: | 3932 SW FLINTROCK DR, LEES SUMMIT, MO 64082 |
| Parcel Number: | 277630 |
| Location: | |
| Type of Work: | NEW SINGLE FAMILY |
| Occupancy Group: | RESIDENTIAL, ONE- AND TWO-FAMILY |
| Description: | NEW HOUSE - FINISHED AND UNFINISHED BASEMENT - COVERED PATIO - SUSPENDED STOOP |

Revisions Required

The following is a list of requirements from the City of Lee's Summit that have not been satisfactorily addressed in the plans and specifications. Please address the comments as requested and upload the revised documents and/or additional information to the application through the online portal. Please contact the Development Services Department with any questions you may have.

Development Services Department (816) 969-1200

Plot Plan Review Reviewed By: Brandon Kalwei Rejected

1. Deck location, with dimensions to property lines must be provided on the plot plan. NEEDS TO BE A MINIMUM OF 30' FROM REAR PROPERTY LINE

2. A as-graded plot plan per Section 7-160, Code of Ordinances, is required prior to occupancy. DUE TO FIELD INLET

Residential Plan Review Reviewed By: Brandon Kalwei Rejected

1. One (1) complete permit application. PLANS SHOW SUSPENDED SLAB, NOT MARKED ON APPLICATION. MILLER PLUMBING(?) IS NOT AN HVAC CONTRACTOR, ONLY PLUMBING

2. Two (2) copies of construction drawings. (Plans to be signed and sealed by an architect or engineer registered in the State of Missouri.) PLANS NOT SIGNED AND SEALED.

3. Footings, column pads, piers and grade beams - dimensions. (IRC Section R403) ONLY ONE COLUMN PAD CALLED OUT. NO DETAIL FOR GRADE BEAM. NO DETAIL FOR GARAGE PADS

220 SE Green Street | Lee's Summit, MO 64063 |816.969.1200 | 816.969.1201 Fax | cityofLS.net/Development

4. Footings, column pads, piers and grade beams - reinforcement size and spacing. ONLY ONE COLUMN PAD CALLED OUT. NO DETAIL FOR GRADE BEAM . NO DETAILS FOR GARAGE PAD

| Planning Review RES | Reviewed By: | Pending |
|---------------------|--------------|---------|
|---------------------|--------------|---------|

The review conducted by the City of Lee's Summit Development Services Department shall not be construed as a structural review of the project.

| Residential Area: | | | | | |
|--|-----------|---------------------|------|--|--|
| Residential, Finished basements | | 963 | | | |
| Residential, garage | | 688 | 688 | | |
| Residential, Living Area (Not Finished | Basement) | 1495 | 1495 | | |
| Residential, Un-Finished basements | | 412 | 412 | | |
| | | | | | |
| Roofing Material | | Number of Bathrooms | 3 | | |
| Number of Bedrooms | 4 | Number of Stories | 1 | | |
| Number of Living Units | 1 | Total Living Area | 2458 | | |
| | | | | | |