

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20244826

Address: 1421 SW WINTHROP TER, LEES SUMMIT, MO 64081
1419 SW WINTHROP TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|---------------|----------|---------------------------|
| All Rough Inspection - Residential | Shawn Hoffman | Failed | Friday, February 07, 2025 |

Corrective Action Required:

| | | |
|---|------|---|
| 1 | Misc | 1419 - Provide security blocking at front door hinges side |
| | | 1421 - provide security blocking at front door, hinges side - Missing nails in joist hangers in basement hallway near stairs - No pressure on gas line |

NOT DONE Shawn Hoffman 02/07/2025 8:14 AM

Comments: