

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20241620
Address: 1809 SW HIGHTOWN DR, LEES SUMMIT, MO 64082

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
Occupancy Inspection - Codes Residential	Kyle Beard	Failed	Friday, February 07, 2025

Corrective Action Required:

2 Miscellaneous
Correction

Basement to intermediate landing needs to a light switch (3 way) installed .
There are more than 6 risers and needs to have proper illumination (R303.7)

Pay \$75 fee associated with this permit

Comments: