

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20245090
Address: 2775 SW 11TH TER, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

| Inspection: | Inspector: | Outcome: | Date: |
|---|---------------|----------|------------------------------|
| Erosion Control Inspection Residential | Shawn Hoffman | Failed | Friday, February 07, 2025 |

| | |
|-----------------------------|--|
| Corrective Action Required: | |
| 3 DCM2 ESC | DEFICIENT EROSION CONTROL INSTALLATION. NO FURTHER INSPECTIONS |
| DEFICIENT | UNTIL ADEQUATE EROSION CONTROL PROVIDED. |
| INSTALLATION | |

Comments: