



Olathe
1700 East 123rd Street
Olathe, KS 66061
Phone: 913-829-0078
Fax: 913-829-0258

Client:
City of Lee's Summit MO
Accounts Payable
220 SE Green St
Lees Summit, MO 64063-2706

Project:
L22-05531
LSMO Water Utilities Facility Canopies
1200 Southeast Hamblen Road
Lee's Summit, MO

General Information

Project Phase: Special Inspections

Technician: Wilson, Christy

Temperature (°F): 62

Date: 10/22/2024

Weather: Clear

Arrival Time: 07:00

Departure Time: 08:00

Work Completed

Inspection Item: Post-Installed Anchors

Frequency: Continuous

Location:

Tests Performed: Visual

West Covered Storage Bins - Existing wall at pilaster locations,
Grids D1 to F2

Work Completed Description:

As requested, Olsson arrived on-site to observe the installation of anchors at the above referenced locations. The holes were drilled prior to arrival and appeared to extend to depths of at least 14 inches. The holes were cleaned prior to epoxy placement. The placement of the epoxy and anchors appeared to be as specified.

The contractor used HY500 epoxy instead of the specified HY200. This change was approved by the structural engineer in an email dated 10/22/2024.

Determination

☒ Discrepancy Noted ☐ As Specified ☐ Not Applicable

Discrepancy Number: 1

Status: Closed

The contractor used HY500 epoxy instead of the specified HY200.

Resolution Date: 10/22/2024

Resolved By: Wilson, Christy

This change was approved by the structural engineer in an email dated 10/22/2024.

Client:

City of Lee's Summit MO
Accounts Payable
220 SE Green St
Lees Summit, MO 64063-2706

Project:

L22-05531
LSMO Water Utilities Facility Canopies
1200 Southeast Hamblen Road
Lee's Summit, MO



Image Description: Drilled holes at Grid D1



Image Description: Epoxy placement at Grid E1

Christy Wilson

Christy Wilson
Project Engineer
10/23/2024