



Facility : Lee's Summit Medical Center
Project: Medsurg & Dietary Expansion

DGL Project No: 6406.24.0001
Date: 02/06/2025

ADDENDUM "B" DESIGN COORDINATION

#	Sheet #	Revision Narrative
CIVIL & LANDSCAPE		
1	C0.0	Updated sheet index.
2	C3.0	Updated Key Note table and "E8" callout.
3	C3.1	Updated Key Note table.
4	C4.0	Updated Key Note table.
5	C4.1	Updated Key Note table.
6	C4.2	Updated Key Note table.
7	C5.0	Updated Key Note table.
8	C5.1	Updated Key Note table.
9	C5.2	Updated Key Note table.
10	C6.0	Updated Key Note & Structure tables.
11	C6.1	Updated Key Note table.
12	C6.2	Updated Key Note table.
13	C6.3	Updated Key Note table.
14	C6.4	Updated Key Note table.
15	C7.0	Added note to reference sheet 7.1.
16	C7.1	Added "U27" callouts for thrust blocking.
17	C8.0	Removed NDS Inlet detail.
18	C8.2	Added Nyoplast structure details and shifted elevated walk detail.
19	L1.0	Updated Plant Schedule.
20	L1.1	Updated "L3" & "L4" callouts.
21	L1.2	Updated "L1" callout and planting quantities.

STRUCTURAL		
1	S121	Added key plan. Modified sheet note #2 to include a dimension instead of placeholder. Added new slab for slopes to kitchen floor troughs.
2	S122	Added Key plan. Removed refrigeration rack. Added partial roof plan for new refrigeration rack support.
3	S123A	Added key plan.
4	S123B	Added key plan.
5	S124A	Added key plan. Revised beam size.
6	S124B	Added key plan. Added beam tag.
7	S201	Added detail 14.
8	S211	Detail 1: Revised grid callout.
9	S302	Detail 9: Revised based on coordination with pre-fab wall panel vendor.
ARCHITECTURAL		
1	GI000	Added submittal titles and date for City and Design Coordination.
2	GI001	Updated sheet index.
3	AD101	Added column grids for reference. Added Keynote D31 for lockers, D33 for casework/furniture and D34 for door. Removed equipment background and added Keynote D32. Added several keynotes for clarification.
4	AD103	Added section 1/AD311 reference tag for clarification of existing wall demolition scope.
5	AD104	Revised Keynote D26 to D25. Added demo sections and keynotes for clarification.
6	AD311	New sheet added to show demolition sections for clarification.
7	AE111	Revised Keynote 36 in Keynote Legend. Plan View 1 - Revised detail callout from 10/AE532 to 7/AE531 and added stub-up walls around columns above Mechanical room. Plan View 2 - Adjusted location of section 2/AE311 and revised detail 3/AE533 to 4/AE533.
8	AE121A	Removed Keynote 31 at door 1-1300. Added Keynote 49 on Plan and Keynote Legend to Elec 1-1303 for roof access ladder. Added partition tag F2 in Dining Expansion 1-1300.
9	AE123A	Revised/clarified dimensions. Moved exterior walls for pre-fab panel vendor coordination and adjusted furring walls. Added Keynote Legend for Keynotes 52 and 57. Added door tags.

10	AE123B	Revised/clarified dimensions. Moved exterior walls for pre-fab panel vendor coordination and adjusted furring walls. Adjusted tags that were overprinted.
11	AE131A	Deleted Keynote 36 on Plan and Keynote Legend, does not apply. Added Keynote 49 on Plan and Keynote Legend to Elec 1-1303. Added Keynote 35 to two windows adjacent to Cooler 1-1307.
12	AE133A	Revised partition locations at Stair 3. Added door tags. Added exterior elevation callouts. Added detail 6/AE502.
13	AE133B	Added 'SIM' to callouts 10/AE401, 5/AE402 & 17/AE402. Added exterior elevation callouts.
14	AE143	Revised slab openings to align with Mechanical. Added Keynote Legend for Keynote 47. Revised spot elevation from 1 1/4" to -1 1/4".
15	AE144	Revised slab openings to align with Mechanical. Added Keynote Legend for Keynote 47.
16	AE181A	Added Keynote 56 to Keynote Legend and Cooler and Freezer rooms. Removed, added, shifted diffusers to align with Mechanical.
17	AE183A	Adjusted ceilings for exterior panel shifts. Added dimensions in gyp ceilings. Revised detail over print. Revised HVAC locations per mechanical. Added missing diffusers and return terminals per mechanical. See Reflected Ceiling General notes for typical ceiling heights.
18	AE183B	Adjusted ceilings for exterior panel shifts. Added dimensions in gyp ceilings. Revised diffusers and return terminals locations per mechanical. Added missing stair light fixture per Electrical. Revised missing diffuser per mechanical. Revised exit sign location per Electrical.
19	AE201	Revised material R-01 to include stone in Material Legend.
20	AE202, AE203	Added material tags for E-01.
21	AE303	Deleted incorrect section call out 2/AE331
22	AE312	Added detail tags to wall section 2. Revised roof system note. Cleaned up annotations per wall shifts.

23	AE331	Revised details 1/AE331 & 2/AE331 to show concrete curbs.
24	AE361	Deleted detail callouts 8/AE760.
25	AE502	Added Detail 6 and revised panel connection details per panel vendor coordination.
26	AE601	Revised Legend, changed abbreviation for Existing. Revised door 1-1312.
27	AE602	Revised door rating on 2034 & 2062. Added door rating to other doors clouded on Door Schedule. Added door 3-COR5.
28	AE651	Revised details for window 'Q'. Revised door detail callout tag from 9/AE671 to 13/AE621 on Storefront elevation.
29	AE673	Added sheet to set.
30	AE741	Revised details 6, 9 and 12. Added details 13, 14, 15.

INTERIORS

1	AF001	WALL PROTECTION ITEMS: END WALL GUARD FULL HEIGHT: VOIDED REVISED ACT5 NUMBER.
2	AF001	WALL PROTECTION ITEMS: STAINLESS STEEL CORNER GUARD: UPDATED SPEC
3	AF002	E: TILE :8. UPDATED INSTALLATION OFFSET TO 1/2.
4	AF002	ELEVATION 3-Dietary - TV WALL - UPDATED REFERENCE NUMBER
5	AF002	E: TILE : 9. ADDED TILE ELEVATION
6	AF002	G: CASEWORK DESIGNS 1. FRONT ELEVATION: ADDED ELEVATION REFERENCE
7	AF002	G: CASEWORK DESIGNS 1. SIDE ELEVATION: ADDED ELEVATION REFERENCE
8	AF002	G: CASEWORK DESIGNS 2. GLASS DIVIDER PANEL ELEVATION: ADDED ELEVATION REFERENCE
9	AF101	DINING EXPANSION: REMOVED UNNECESSARY ELEVATION SYMBOL
10	AF101	DINING EXPANSION: UPDATED AF002/7 ELEVATION SYMBOL
11	AF101	DINING: UPDATED PLASTIC LAMINATE
12	AF102	KITCHEN, WAREWASH: ALL CORNER GUARDS UPDATED TO STAINLESS STEEL, FULL HEIGHT
13	AF102	WALL PROTECTION ITEMS: END WALL GUARD FULL HEIGHT: VOIDED
14	AF102	WALL PROTECTION ITEMS: STAINLESS STEEL CORNER GUARD: UPDATED SPEC
15	AF105	SIGNAGE PLAN: REMOVED ALL ELEVATION MARKERS
16	AF301A	STAFF LOUNGE 3-2118: UPDATED ELEVATION MARKER
17	AF301A	CORRIDOR 3-2043: REARRANGED TAGS
18	AF301A	CORRIDOR 3-2043: UPDATED AF002/5 ELEVATION SYMBOL
19	AF301A	CORRIDOR 3-2043: UPDATED AF002/6 ELEVATION SYMBOL
20	AF301B	STAFF LOUNGE 3-2118: UPDATED ELEVATION MARKER
21	AF301B	NURSE ALC 3-2085C, 3-2085D, 3-2086E, 3-2086B, 3-2086C: UPDATED ACCENT PAINT IN EACH NURSE ALCOVE
22	AF302A	STAIR 3-ST4: UPDATED RF FLOORING CODE
23	AF302A	SOILED HOLD 3-2039: UPDATED CORNER GUARD TO FULL HEIGHT
24	AF302A	WALL PROTECTION ITEMS: END WALL GUARD FULL HEIGHT: VOIDED
25	AF302B	WALL PROTECTION ITEMS: STAINLESS STEEL CORNER GUARD: UPDATED SPEC
26	AF302B	SOILED HOLD 3-2081: UPDATED CORNER GUARD TO FULL HEIGHT
27	AF302B	WALL PROTECTION ITEMS: END WALL GUARD FULL HEIGHT: VOIDED
28	AF303A	WALL PROTECTION ITEMS: STAINLESS STEEL CORNER GUARD: UPDATED SPEC
29	AF303B	2: FLOOR PATTERN PLAN - ADA PAT/TLT RM, TYP.: UPDATED TS AT PAT TLT 3-2003
30	AF303B	4: LEVEL 3 - FLOOR PATTERN PLAN - ADA PAT/TLT RM, TYP.: PAT TLT ADA 3-2074: UPDATED FLOOR MATERIAL
31	AF303B	4: LEVEL 3 - FLOOR PATTERN PLAN - ADA PAT/TLT RM, TYP.: UPDATED FLOOR TRANSITIONS

PLUMBING

1	PD02-03A	Updated legend notes to match legend tags on plan.
2	P02-01	Demolished existing floor sink. Kitchen fixtures are scheduled in kitchen consultant drawings, provided legend note for reference. Added pipe tag.
3	P02-02B	Updated overlapping pipe tags.
4	P02-03A	Moved legend tag close to associated pipe tags. Updated misspelled legend note.

MECHANICAL

1	M02-01	Updated legend notes to delete ones that were not used on plan. Deleted an extra VAV tag.
2	M02-03B	Updated location of BAS panel to match the location shown on E02-03B.
3	M03-01	Updated legend notes to delete ones that were not used on plan.
4	M03-03B	Updated legend notes to delete ones that were not used on plan. Added PHP-1 from 'PUMP SCHEDULE' to the floor plan.
5	M05-01	Updated location of BAS panel to match the location shown on E02-03B.
6	M06-01	Updated cfm of GEF-29 on 'AIR RISER DIAGRAM'.
7	M08-01	Updated 'AIR DEVICE SCHEDULE'.
8	M08-03	Updated 'FAN COIL UNIT SCHEDULE' AND 'SPLIT SYSTEM A/C UNIT SCHEDULE'.
9	M08-04	Updated 'STEAM SYSTEM ACCESSORIES SCHEDULE'.

ELECTRICAL

1	E01-01	Updated light fixture tags.
2	E01-02	Updated equipment tags to match latest kitchen vendor drawings.
3	E02-03A	Updated keynote to clarify fire smoke damper locations.
4	E02-03B	Added equipment tag to AHU-12. Updated keynote to clarify fire smoke damper locations.
5	E03-03A	Updated light fixture tags.
6	E03-03B	Updated exit sign location to match architect.
7	E04-03A	Added Legend Note to clarify fire smoke damper location.
8	E04-03B	Added Legend Note to clarify fire smoke damper location.
9	E05-02	Updated detail reference in Legend Note #8 to clarify overbed lighting controls.
10	E06-01	Updated new panelboard number of sections to match what is shown on E5 and E8 series.
11	E06-02	Updated out of scope shading to clarify new scope.
12	E06-03	Updated out of scope shading to clarify new scope. Updated new panelboard number of sections to match what is shown on E5 and E8 series. Updated AHU equipment number to match mechanical schedule.
14	E07-02	Added detail #4.
14	E08-02	Removed light fixture types not used in project scope.
15	E08-04	Added new panelboard 'M1ELKB' location to panelboard schedule.

TECHNOLOGY		
1	TD02-01	Updated Legend Notes to match demolition scope.
SPECIFICATION SECTIONS		
1	COVER	Revised Cover
2	000001	Revised Table of Contents
3	013100	Revised/Re-coordinate section number
4	013200	Revised/Re-coordinate section number
5	013233	Revised/Re-coordinate section number
6	013300	Revised/Re-coordinate section number
7	055213	Page 1 - 1.1 B. - Revised Section number for Metal Pan Stairs.
8	061643	Removed sections under "related requirements" that are not applicable to project.
9	064116	Removed sections under "related requirements" that are not applicable to project.
10	072116	Removed sections under "related requirements" that are not applicable to project.
11	072610	Revised section number 072600 to 072610.
12	074263.16	Removed sections under "related requirements" that are not applicable to project.
13	077200	Page 4 - 2.5 ROOF HATCHES - Added Basis of Design for different size hatch for Dietary roof. Page 5 - Added #6 for Bil-Guard Railing System.
14	078443	Removed sections under "related requirements" that are not applicable to project.
15	088113	Removed sections under "related requirements" that are not applicable to project.
16	087100	Revised hardware sets per bid RFIs.
17	092116	Revised related requirements section 078413 to 078400 Firestopping.
18	095423	Page 5 - 2.2.1, A. Revised AMP to ACT5 to align with Ceiling Schedule.
19	096513	Removed sections under "related requirements" that are not applicable to project. Removed resilient stair accessories section.
20	096516	Removed sections under "related requirements" that are not applicable to project.
21	096519	Removed sections under "related requirements" that are not applicable to project.
22	096813	Revised installation method section for clarification.
23	099100	Revised paint types to coordinate with interior finish drawings and paint tags.