

CITY OF LEE'S SUMMIT
Development Services Department
220 SE Green Street
Lee's Summit, MO 64063
(816)969-1200
DEVSERVICES.CITYOFLS.NET

Inspection Summary

Permit #: PRRES20242933
Address: 2218 NW KILLARNEY LN, LEES SUMMIT, MO 64081

This work has been inspected and the inspection results noted below. Please schedule inspections once all corrective actions have been completed. Do not cover any work until approved.

Inspection:	Inspector:	Outcome:	Date:
All Rough Inspection - Residential	Robb Popp	Failed	Monday, February 10, 2025

Informational:		
1	Miscellaneous Correction	-Strap top plate lapping less than 24" at exterior corner of mechanical room-THIS IS AT THE EXTERIOR CORNER. THE BOTTOM TOP PLATE IS ROUGHLY 2" LONG.

Comments: